

DESIGN & BUILD OF INTERIOR FIT-OUT WORKS FOR EXISTING

SUBMITTAL COMPLIANCE FORM

Contractor:	Submittal No:		
Sub-Contractor/	Rev:		
Manufacturer: LANDIS+GYR	Spec Reference:		
Plot No.			
S/No	CONTRACT / SPECIFICATION REQUIREMENTS	COMPLIANCE	REMARKS
1	BTU energy meter, ultrasonic type.	Comply	Landis+Gyr UH50
2	Connection: threaded/flanged as per design.	Comply	G2B / DN50
3	Flow rate capacity as specified.	Comply	10 & 15 m ³ /h
4	Pressure rating min. PN16/PN25.	Comply	PN16 / PN25
5	Temp sensors: Pt500 immersion Ø6×100.	Comply	2 m cable
6	Split calculator with 1.5 m cable.	Comply	As quoted
7	Battery powered, min. 6-year life.	Comply	6-year D-cell
8	Communication interface: M-Bus.	Comply	Module G4
9	Country of origin: Germany.	Comply	Make: Landis+Gyr
10	Submit datasheet + installation manual.	To be provided	With submittal
11	Submit warranty + conformity certificates.	To be provided	CE / equivalent
12	Submit calibration/test certificate if required.	To be provided	Upon request
13			
14			
15			
16			
17			
18			
19			
20			
21			
22			
23			
24			
25			
26			
27			
28			
29			
30			
31			
32			
33			
34			
35			
36			
37			
38			
39			
40			